

CHORLEY BUNCE Ltd

Tick One Box	
High	<input type="checkbox"/>
Med	<input checked="" type="checkbox"/>
Low	<input type="checkbox"/>

Date of Assessment: OCT 2017

Review Date: OCT 2018

Record/Assessment No: 5

Signature of Assessor: 

RISK ASSESSMENT FORM FOR:

ASSESSMENT UNDERTAKEN: Use of L.P.G. - Liquid Petroleum Gas Cylinders

Hazards	Persons at Risk	Existing and Required Controls including Documented Standards and Training	Further Action Required?
<p>Fire</p> <p>Explosion</p> <p>Manual Handling</p> <p>Cold (giving rise to cold burns)</p> <p>Oxygen deficiency (Asphyxiation)</p>	<p>Staff</p> <p>Visitors</p> <p>Contractors</p>	<p>Competent Persons</p> <p>Level of Supervision</p> <p>Use in accordance with manufacturer's literature</p> <p>Cylinders must be secured and stored to protect against collision or falling and not tampered with</p> <p>Cylinder valves to be free of dirt or grease and fully protected from accidental or deliberate damage</p> <p>Limit control on number of cylinders available</p> <p>No smoking in vicinity</p> <p>Connectors and valves and flexible tubing to be affixed so as not to cause harm</p> <p>Visual inspection of cylinders before, during and after use</p> <p>Do not use if connectors or flexible pipelines are damaged</p> <p>Where used by contractors then ensure 'contractor controls' are enforced and a contractor is in attendance to establish security of the cylinders</p> <p>General ventilation</p> <p>Don't use cylinder inside a marquee</p> <p>Keep combustibles and rubbish away from the LPG cylinders</p> <p>Segregation and separation</p> <p>Use away from the public and vehicle access</p> <p>Evacuate if a leak develops and call emergency number</p> <p>If a leak develops and it is safe to do so then turn off valve</p> <p>See RA Storage of LPG</p>	